

## Hevadex bvba

Alfons Braeckmanlaan 237A  
Oost-Vlaanderen  
9040  
Belgium

Tel: +32 934 83100 Fax: +32 927 03344

e-mail: info@hevadex.be

website: www.hevadex.be



**Agrément Certificate**

**17/5410**

Product Sheet 2

### SPRAY, ROLLER OR BRUSH APPLIED FLEXIBLE MEMBRANES FOR DURABLE AIRTIGHTNESS

### BLOWERPROOF LIQUID BRUSH

This Agrément Certificate Product Sheet<sup>(1)</sup> relates to Blowerproof Liquid Brush, for use as an airtightness membrane.

(1) Hereinafter referred to as 'Certificate'.

#### CERTIFICATION INCLUDES:

- factors relating to compliance with Building Regulations where applicable
- factors relating to additional non-regulatory information where applicable
- independently verified technical specification
- assessment criteria and technical investigations
- design considerations
- installation guidance
- regular surveillance of production
- formal three-yearly review.



#### KEY FACTORS ASSESSED

**Air permeability** — the product will reduce uncontrolled air infiltration from or into the building (see section 6).

**Resistance to mechanical damage** — the product will accommodate the movement likely to occur in service (see section 8).

**Durability** — the product will have a service life equal to that of the element onto which it is installed (see section 12).



The BBA has awarded this Certificate to the company named above for the product described herein. This product has been assessed by the BBA as being fit for its intended use provided it is installed, used and maintained as set out in this Certificate.

On behalf of the British Board of Agrément

Date of First issue: 22 March 2017

John Albon – Head of Approvals  
Construction Products

Claire Curtis-Thomas  
Chief Executive

The BBA is a UKAS accredited certification body – Number 113.

The schedule of the current scope of accreditation for product certification is available in pdf format via the UKAS link on the BBA website at [www.bbacerts.co.uk](http://www.bbacerts.co.uk)  
Readers are advised to check the validity and latest issue number of this Agrément Certificate by either referring to the BBA website or contacting the BBA direct.

#### British Board of Agrément

Bucknalls Lane  
Watford  
Herts WD25 9BA

tel: 01923 665300

fax: 01923 665301

[clientservices@bba.star.co.uk](mailto:clientservices@bba.star.co.uk)

[www.bbacerts.co.uk](http://www.bbacerts.co.uk)

©2017

## Regulations

In the opinion of the BBA, Blowerproof Liquid Brush, if installed, used and maintained in accordance with this Certificate, can satisfy or contribute to satisfying the relevant requirements of the following Building Regulations (the presence of a UK map indicates that the subject is related to the Building Regulations in the region or regions of the UK depicted):



### The Building Regulations 2010 (England and Wales) (as amended)

<b>Requirement:</b>	L1(a)(i)	<b>Conservation of fuel and power</b>
<b>Comment:</b>		The product will contribute to satisfying this Requirement. See section 6 of this Certificate.
<b>Regulation:</b>	7	<b>Materials and workmanship</b>
<b>Comment:</b>		The product is acceptable. See section 12 and the <i>Installation</i> part of this Certificate.
<b>Regulation:</b>	26	<b>CO<sub>2</sub> emission rates for new buildings</b>
<b>Regulation:</b>	26A	<b>Fabric energy efficiency rates for new dwellings (applicable to England only)</b>
<b>Regulation:</b>	26A	<b>Primary energy consumption rates for new buildings (applicable to Wales only)</b>
<b>Regulation:</b>	26B	<b>Fabric performance values for new dwellings (applicable to Wales only)</b>
<b>Comment:</b>		The product will contribute to satisfying these Regulations but additional fabric/services measures will be required. See section 6 of this Certificate.



### The Building (Scotland) Regulations 2004 (as amended)

<b>Regulation:</b>	8(1)	<b>Durability, workmanship and fitness of materials</b>
<b>Comment:</b>		The product satisfies the requirements of this Regulation. See section 12 and the <i>installation</i> part of this Certificate.
<b>Regulation:</b>	9	<b>Building standards applicable to construction</b>
<b>Standard:</b>	6.1(b)	Carbon dioxide emissions
<b>Comment:</b>		The product will contribute to satisfying this Standard with reference to clauses 6.1.1 <sup>(1)</sup> , 6.1.6 <sup>(1)</sup> and 6.1.2 <sup>(2)</sup> but additional fabric/services measures will be required. See section 6 of this Certificate.
<b>Standard:</b>	6.2	Building insulation envelope
<b>Comment:</b>		The product will contribute to satisfying this Standard with reference to clauses 6.2.4 <sup>(1)</sup> and 6.2.6 <sup>(2)</sup> . See section 6 of this Certificate.
<b>Standard:</b>	7.1(a)(b)	Statement of sustainability
<b>Comment:</b>		The product can contribute to meeting the relevant requirements of Regulation 9, Standards 1 to 6, and therefore will contribute to a construction meeting a bronze level of sustainability as defined in this Standard. In addition, the product can contribute to a construction meeting a higher level of sustainability as defined in this Standard, with reference to clauses 7.1.4 <sup>(1)</sup> [Aspects 1 <sup>(1)</sup> and 2 <sup>(1)</sup> ], 7.1.6 <sup>(1)(2)</sup> [Aspects 1 <sup>(1)(2)</sup> and 2 <sup>(1)</sup> ], 7.1.7 <sup>(1)</sup> [Aspect 1 <sup>(1)(2)</sup> ] 7.1.9 <sup>(2)</sup> [Aspect 1 <sup>(2)</sup> ] and 7.1.10 <sup>(2)</sup> [Aspect 1 <sup>(2)</sup> ]. See section 6 of this Certificate.
<b>Regulation:</b>	12	<b>Building standards applicable to conversions</b>
<b>Comment:</b>		All comments given for the product under Regulation 9, Standards 1 to 6, also apply to this Regulation, with reference to clause 0.12.1 <sup>(1)(2)</sup> and Schedule 6 <sup>(1)(2)</sup> .

(1) Technical Handbook (Domestic).

(2) Technical Handbook (Non-Domestic).



## The Building Regulations (Northern Ireland) 2012 (as amended)

<b>Regulation:</b>	<b>23(a)(i)</b>	<b>Fitness of materials and workmanship</b>
<b>Comment:</b>	<b>(iii)(b)</b>	The product is acceptable. See section 12 and the <i>Installation</i> part of this Certificate.
<b>Regulation:</b>	<b>39(a)(i)</b>	<b>Conservation measures</b>
<b>Comment:</b>		The product will contribute to satisfying this Regulation. See section 6 of this Certificate.
<b>Regulation:</b>	<b>40(2)</b>	<b>Target carbon dioxide emission rate</b>
<b>Comment:</b>		The product will contribute to satisfying this Regulation but additional fabric/services measures will be required. See section 6 of this Certificate.

## Construction (Design and Management) Regulations 2015

## Construction (Design and Management) Regulations (Northern Ireland) 2016

Information in this Certificate may assist the client, designer (including Principal Designer) and contractor (including Principal Contractor) to address their obligations under these Regulations.

See section: **3 Delivery and site handling (3.1 and 3.4)** of this Certificate.

## Technical Specification

### 1 Description

1.1 Blowerproof Liquid Brush is a VOC-free, liquid-applied, water-based coating that dries to form a flexible membrane that is used to reduce uncontrolled air infiltration from or into a building.

1.2 Other items or components which may be used with the product, but which are outside the scope of this Certificate, are:

- spray foam or cementitious fillers, for sealing large cracks.

Details of suitable products/specifications may be obtained from the Certificate holder.

### 2 Manufacture

2.1 The product is manufactured by a typical batch process.

2.2 As part of the assessment and ongoing surveillance of product quality, the BBA has:

- agreed with the manufacturer the quality control procedures and product testing to be undertaken
- assessed and agreed the quality control operated over batches of incoming materials
- monitored the production process and verified that it is in accordance with the documented process
- evaluated the process for management of nonconformities
- checked that equipment has been properly tested and calibrated
- undertaken to carry out the above measures on a regular basis through a surveillance process, to verify that the specifications and quality control operated by the manufacturer are being maintained.

### 3 Delivery and site handling

3.1 The product is delivered to site in 5 kg pails on pallets, maximum 60 pails per pallet. The product can also be supplied in 2.5 kg, 310 ml and 600 ml packs if required.

3.2 Each pail is labelled with product name, pack weight, company name, batch number and brief installation instructions.

3.3 The product should be stored at a temperature between 5°C and 20°C in dry conditions and out of direct sunlight. When stored in unopened containers, in accordance with the Certificate holder's instructions, the product will have a shelf life of 12 months.

3.4 The Certificate holder has taken the responsibility of classifying and labelling the product under the *CLP Regulation (EC) No 1272 / 2008 on the classification, labelling and packaging of substances and mixtures*. Users must refer to the relevant Safety Data Sheet(s).

## Assessment and Technical Investigations

The following is a summary of the assessment and technical investigations carried out on Blowerproof Liquid Brush.

### Design Considerations

## 4 Use

4.1 Blowerproof Liquid Brush is satisfactory for use internally as a membrane, to reduce the uncontrolled air infiltration from or into a building.

4.2 The product can be used to reduce air permeability on or at:

- air permeable walls, eg block walls
- floor/wall connections
- wall/roof connections
- wall/wall connections
- window frame/wall connections
- penetrations.

4.3 Airtightness sealing of large areas, eg block walls, should be carried out using Blowerproof Liquid, the subject of Product Sheet 1 of this Certificate.

4.4 Existing elements must be clean, dry and in a good state of repair prior to the application of the product.

4.5 The product is applied by brush at an application rate of between 0.8 and 1.0 kg·m<sup>-2</sup> resulting in a dry film thickness of between 0.4 and 0.5 mm.

4.6 The product once fully dry can be finished by painting, plastering or enclosed behind internal linings. The Certificate holder must be consulted for suitable compatible products.

## 5 Practicability of installation

The product is designed to be installed by a contractor experienced with this type of product.

## 6 Air permeability



The product will reduce uncontrolled air infiltration from or into a building and will therefore reduce heat loss through elements and junctions.

## 7 Water vapour resistance

7.1 Typically the water vapour diffusion equivalent air layer thicknesses ( $s_d$ )<sup>(1)</sup> of the cured, unaged product with a thickness of 0.5 mm, can be taken as 18 m.

(1) Measured at 0/50 % relative humidity difference across the specimen at (23 ± 2)°C.

7.2 The water vapour resistance of the product will vary, depending on the relative humidity difference across it. A condensation risk analysis should be carried out prior to use of the product.

## 8 Resistance to mechanical damage

8.1 The product has satisfactory resistance to damage and will resist the minor movements likely to occur in service without damage.

8.2 Where large relative movements between construction elements are possible, such as in timber-frame construction, the advice of the Certificate holder should be sought.

## 9 Properties in relation to fire

The product, brush-applied to a 12 mm thick calcium silicate panel of density  $870 \text{ kg}\cdot\text{m}^3$ , achieved a reaction-to-fire classification of E to BS EN 13501-1 : 2007.

## 10 Adhesion

10.1 The product has satisfactory adhesion to the following substrates:

- concrete
- lightweight concrete block
- red brick
- aluminium
- steel
- wood
- plaster
- EPDM membrane
- PVC-U.

10.2 The adhesion on other substrates should be confirmed by test.

## 11 Maintenance

As the product is confined within the structure and has suitable durability (see section 12), maintenance is not required. However, any damage to the membrane should be repaired before enclosing into the structure (see section 15).

## 12 Durability



Under normal conditions of use, the product has satisfactory durability and will have a life equal to that of the element onto which it is installed.

## Installation

### 13 General

13.1 Installation of Blowerproof Liquid Brush must be in accordance with the Certificate holder's instructions.

13.2 Surfaces must be free from salt efflorescence, dust and other loose particles or any other contamination that could affect the adhesion of the product. The product can be applied to lightly damp surfaces but must not be applied where there is standing water.

13.3 Existing holes and cracks must be sealed with a cementitious filler or polyurethane spray foam. Small holes and cracks up to 5 mm can be sealed with the product.

13.4 The product must not be applied when the air or substrate temperature is <5°C.

## 14 Procedure

14.1 The product is applied to the prepared substrate by brush, to achieve a wet film thickness of between 800 and 1000 µm.

14.2 The applied coating thickness should be checked using a wet film gauge and the application checked for complete coverage.

14.3 The drying time will depend on the substrate as well as the ambient temperature and relative humidity. Typically the product will be dry 24 to 48 hours after application.

## 15 Repair

Any damaged coating must be repaired prior to enclosure. Minor damage to the dry product can be repaired by reapplying the product over the damaged area, as described in sections 14.1 and 14.2. Where major damage has occurred, the damaged section must be cut out and the membrane reapplied, ensuring a minimum 50 mm overlap onto sound material.

## Technical Investigations

## 16 Tests

16.1 Tests were carried out to establish:

- IR spectroscopy
- thermogravimetric analysis
- resistance to fatigue
- tensile strength/elongation.

## 17 Investigations

17.1 An assessment was made of test reports from independent test laboratories relating to:

- reaction to fire
- air permeability
- adhesion to substrates
- water vapour resistance
- tensile strength/elongation.

17.2 A visit was made to an established installation in Belgium to witness airtightness testing and to assess the product's performance in service. The assessed building was an office building that was tested at the end of the construction phase and after three years, meeting the passive house requirements for air permeability in both cases.

17.3 The manufacturing process was evaluated, including the methods adopted for quality control, and details were obtained of the quality and composition of the materials used.

## Bibliography

BS EN 13501-1 : 2007 *Fire classification of construction products and building elements — Classification using test data from reaction to fire tests.*

### 18 Conditions

#### 18.1 This Certificate:

- relates only to the product/system that is named and described on the front page
- is issued only to the company, firm, organisation or person named on the front page – no other company, firm, organisation or person may hold claim that this Certificate has been issued to them
- is valid only within the UK
- has to be read, considered and used as a whole document – it may be misleading and will be incomplete to be selective
- is copyright of the BBA
- is subject to English Law.

18.2 Publications, documents, specifications, legislation, regulations, standards and the like referenced in this Certificate are those that were current and/or deemed relevant by the BBA at the date of issue or reissue of this Certificate.

18.3 This Certificate will remain valid for an unlimited period provided that the product/system and its manufacture and/or fabrication, including all related and relevant parts and processes thereof:

- are maintained at or above the levels which have been assessed and found to be satisfactory by the BBA
- continue to be checked as and when deemed appropriate by the BBA under arrangements that it will determine
- are reviewed by the BBA as and when it considers appropriate.

18.4 The BBA has used due skill, care and diligence in preparing this Certificate, but no warranty is provided.

18.5 In issuing this Certificate the BBA is not responsible and is excluded from any liability to any company, firm, organisation or person, for any matters arising directly or indirectly from:

- the presence or absence of any patent, intellectual property or similar rights subsisting in the product/system or any other product/system
- the right of the Certificate holder to manufacture, supply, install, maintain or market the product/system
- actual installations of the product/system, including their nature, design, methods, performance, workmanship and maintenance
- any works and constructions in which the product/system is installed, including their nature, design, methods, performance, workmanship and maintenance
- any loss or damage, including personal injury, howsoever caused by the product/system, including its manufacture, supply, installation, use, maintenance and removal
- any claims by the manufacturer relating to CE marking.

18.6 Any information relating to the manufacture, supply, installation, use, maintenance and removal of this product/system which is contained or referred to in this Certificate is the minimum required to be met when the product/system is manufactured, supplied, installed, used, maintained and removed. It does not purport in any way to restate the requirements of the Health and Safety at Work etc. Act 1974, or of any other statutory, common law or other duty which may exist at the date of issue or reissue of this Certificate; nor is conformity with such information to be taken as satisfying the requirements of the 1974 Act or of any statutory, common law or other duty of care.